



3095 Main Street • Caledonia, NY 14423 • 585-538-2253

Monthly Report October-2021

WATER

Total Gallons:	6,447,000
Daily Average:	208,000
October-20	5,744,000

10/5/2021 Sample:	Negative
10/19/2021 Sample:	Negative

WATER DISTRIBUTION SYSTEM

Church Street Water Main project designed and approved by the LCDOH.
Checked sump pumps and winterized all meter vaults.
Repaired water leak at 3089 Main Street.
Repaired water leak at 3263 Ellen Place.

STREETS

Church Street road and drainage designed and forwarded to NYSDOT for approval to tie into the North Street drainage system.
Started leaf pickup.
Finished cleaning out catch basins throughout Village.

EQUIPMENT

Serviced all equipment for fall/winter.
Installed new battery and joystick on leaf machine.

PARKS

Mowing continues.
Closed and winterized all parks.
Porta-John can be removed from Washburn.

BUILDINGS

Normal maintenance continues.
Isaac HVAC performed fall/winter PM

OTHER

Approve Church Street Water Main Replacement Materials Bid.